HIMACHAL PRADESH
PUBLIC WORKS DEPARTMENT

NO.PW-MDII-WA-BUILDING-2025- 2988-89 Dated: 17-02-2026

To

The Principal,
Nobal Collage Building
Pandoh Distt Mandi

Subject:- Building safety certificate in respect Nobal Collage Building Pandoh Mandi H.P.

It is to inform you that as per structural/working drawings of above Collage building, the building has not been constructed under the Supervision of this department, besides to it no detailed structural design calculation and analysis were made available for seismic or non-seismic condition by the Collage authority. However, on visual inspection conducted by the Assistant Engineer, Mandi Sub Division No IV HPPWD Mandi and further reported by him, the building seems to be safe to run the Collage classes for the academic year **2026-28**.

Further no addition & alteration be carried out in the building and if any addition & alteration are required the fresh certificates are required to be obtained.

DA- As above

Executive Engineer,
Mandi Division No.II,
HPPWD, Mandi.

Copy to Assistant Engineer, Mandi Sub Division No IV HPPWD, Mandi w.r.t. his office letter No. 903dated 16/02/2026 for kind information please.

Executive Engineer,
Mandi Division No.II,
HPPWD, Mandi.

SAFETY CERTIFICATSE

The Nobal Collage of Building Vill, Seog, P/O Pandoh, Tehsil Sadar, Distt. Mandi (H.P) has been inspected by the Junior Engineer (Pandoh) on dated 04-02-2026. This building has neither designed nor been constructed under the supervision of this office, no earth quake resistant norms has been adopted for this building. Hence the structural safety of the building cannot be ensured specifically from earth quake point of view and this Department is not responsible for any loss/damage thereof. However as visual inspection the building seems to be safe for running the school for the year 2026-28.

Assistant Engineer,
Mandi Sub-division No-IV,
H.P.P.W.D. Mandi